



ROOF MOUNTED MECHANICAL EQUIPMENT

California Mechanical Code (CMC) Section 910 – Furnaces Installed on Roofs or Exterior Walls

910.1 General – A roof or exterior building wall supporting a furnace shall comply with the requirements for roof and wall structures specified in the Building Code, and the equipment shall be listed or approved for such use.

910.5 Platform – A furnace located on a roof shall be installed on a substantial level platform. When the roof has a slope greater than four (4) in twelve (12), a level-working platform at least thirty (30) inches in depth and width shall be provided along the firebox and control sides of the furnace.

